

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

For the following product(s):

Vinyl Tile:

Luxury Vinyl Tile 1.5mm-5.0mm, Vinyl Compound Plank 5.5mm-6.5mm

This product meets all of the necessary qualifications to be certified for the following claim:

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 V3.0

Conforms to the CDPH/EHLB Standard Method v1.1-2010 (California Section 01350), effective January 1, 2012, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.1-2010)

Registration # SCS-FS-04026

Valid from: June 1, 2016 to May 31, 2017

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Product Guide, <http://www.scsglobal services.com/verified-green-product-guide>.



ANSI ACCREDITED PROGRAM
PRODUCT CERTIFICATION
#0021

Stanley Mathuram, PE, Vice President
SCS Global Services
2009 Powell Street, Ste. 600, Emeryville, CA 94608 USA

